

RETAIL TRADE



MOST CITED STANDARDS IN THE RETAIL INDUSTRY JANUARY 1, 2002 TO DECEMBER 31, 2002

RANK		STANDARDS CITED	NUMBER
1	1910.305(g)	Flexible cords were used as a substitute for fixed wiring where not permitted. Flexible cords were not connected to devices and fittings so that strain relief was provided, which would have prevented pull from being transmitted to joints.	35
2	1910.304	This section contains grounding and overcurrent protection requirements for systems, circuits, and equipment.	26
3	60-2	Safe workplaces and practices were not provided. Standards for an Occupational Safety and Health Program were not met.	23
4	1910.22	Places of employment , passageways, and storerooms were not kept clean and orderly and in a sanitary condition.	22
4	1910.1200	Employers did not develop and implement a written hazard communication program for their work-places. Employers did not have a Material Safety Data Sheet (MSDS) for each hazardous chemical which they used.	22

RANK	STANDARDS CITED	NUMBER
5	1910.178 This section contains safety requirements relating to fork trucks, tractors, platform lift trucks, and motorized hand trucks.	21
6	1910.23 Every stairway floor opening was not guarded by a standard railing in accordance with requirements of this section.	18
7	1910.38 This section applies to emergency-action and fire-prevention plans required by particular HIOSH standards.	16
7	1910.303 Electrical equipment was not free from recognized hazards that were likely to cause death or serious physical harm to employees.	16
8	1910.305(b) Conductors entering boxes, cabinets, or fittings were not protected from abrasion, and openings through which conductors entered were not effectively closed . All pull boxes, junction boxes, and fittings were not provided with covers approved for the purpose.	13
9	1910.132 Personal safety equipment or clothing was not worn by employees who were exposed to hazards where these devices were expected to prevent injury.	9